

**Self-declaration  
on the accuracy of active power measurement**

The company

KOSTAL Solar Electric GmbH  
Hanferstraße 6  
79108 Freiburg i. Br., Germany

hereby declares, that the inverters of type

**PLENTICORE BI, PLENTICORE BI G2,  
PLENTICORE plus , PLENTICORE plus G2,  
PLENTICORE G3**

measure the output active power with an accuracy of  $\leq 2\% P_{nom}$ .

**KOSTAL Solar Electric GmbH – Freiburg, 01.03.2024**

  
KOSTAL Solar Electric GmbH  
Hanferstraße 6  
D-79108 Freiburg  
Tel.: 0761-47744100  
Fax: 0761-47744111

Frank Henn  
(Managing Director)

  
KOSTAL Solar Electric GmbH  
Lange Eck 11 · D-51099 Hagen

i.V. Frank Greizer  
(Head of Department R&D)