

### DECLARATION OF CONFORMITY

We, Santon Holland bv, declare under our sole responsibility that the product:

Santon “**PFSHP-18-MC4, PFSHP-158-MC4(Evo2), PFSHP-18S-MC4, PFSHP-158S-MC4(Evo2)**” (described below), provided that it is installed, maintained and used in the application for which it is made, with respect of the “professional practices”, relevant installation standards and manufacturer’s instructions.



**Domestic Firefighter safety Switch (PFSHP-18-MC4, PFSHP-158-MC4(Evo2), PFSHP-18S-MC4, PFSHP-158S-MC4(Evo2))**

PFSHP-18-MC4	PFSHP-158-MC4(Evo2)		PFSHP-18S-MC4	PFSHP-158S-MC4(Evo2)	
1000	1000	1500	1000	1000	1500
45	45	20	45	45	20
8 poles, 0-1-0-1	8 poles, 0-1-0-1		8 poles, 0-1-0-1	8 poles, 0-1-0-1	
4	4		4	4	

100Vac - 240Vac
230Vac
30mA
average 100mA
max 300mA
24Vdc - 300mA max

N/A	Change over contact	Change over contact
		
	AC-15: 230 V   DC-13: 60 V	AC-15: 230 V   DC-13: 60 V
	1.0 A   0.5 A	1.0 A   0.5 A

-20°C - +50°C
+100°C
-40°C - +85°C
IP65
Class II
EN 60947 part 1+3
IEC: EN 60947-3:2009/A1:2012/C1:2013 /A2:2015 Cat PV -1
9700
300

to which this declaration relates is in conformity with the following standard(s):

IEC 60947 part 1 and 3

complies with the provisions of Council Directive:

73 / 23 / EEC of 19 February 1973 (OJEC L 77 of 26-03-73) modified by Directive 93 / 68 / EEC of 22 July 1993 (OJEC L220 of 30-08-93) so called Low Voltage Directive (LVD) and can be incorporated in equipment coming under application to other Directives.

For Production Certificate ISO 9001:2015 no. NL023762-002 first issued by BVQI on August 28, 2015, Last issued by BVQI on May 07, 2021 valid until November 09, 2023.

Additional information:

This product is intended to be installed, maintained and used by professional or entitled persons.

Year of affixing the “CE” marking: 2006

Manager Q-SHE



F. Christiaan

September 2022