

GoodWe Technologies Co., Ltd.
Mr. Jiang Tao

Date : 29.09.2022
Our ref. : Zhouwils 01
Your ref.: MR. JIANG TAO

No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : Rechargeable Li-ion Battery System
Model Designation : See Certificate
Certificate No. : R 50560449 0001
Report No. : CN22B9UK 001

Dear Mr. Jiang Tao,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area. In case you have a change regarding your involved local representative for the certificate, please inform us in due time.

With kind regards,

Certification Body

Weichun Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50560449

Blatt Sheet
0001

Ihr Zeichen Client Reference
MR. JIANG TAO

Unser Zeichen Our Reference
01-Zhouwils-CN22B9UK 001

Ausstellungsdatum
29.09.2022

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder

GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Fertigungsstätte Manufacturing Plant

GoodWe (GuangDe) Power Supply
Technology Co., Ltd.
No.208, Tong Rui East Road,
Guangde,
Anhui
P.R. China

Prüfzeichen Test Mark



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 111126007

Geprüft nach Tested acc. to

IEC 62619:2017
IEC 63056:2020

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Lithium-Ionen-Akkumulator (Rechargeable Li-ion Battery System)

Type Designation: LX U5.4-20 10
Maximum current of recommended charger [A]: 50
Rated capacity [Ah]: 105
Upper limit charging voltage [Vd.c.]: 57.6
Nominal voltage [Vd.c.]: 51.2
End-of-discharge voltage [Vd.c.]: 47.5
Operating temperature of charge [°C]: 0 to 50
Operating temperature of discharge [°C]: -10 to 50
Ingress Protection (IP): IP65

Remark(s):

The installation has to be carried out according to the attached installation instruction.
Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

10

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Weichun Li